

For Immediate Release: April 8, 2016

**INTERTEK WARNS OF INVALID cETLus CERTIFICATION MARK
ON HID ELECTRONIC BALLAST**

Intertek Testing Services (ETL) notifies consumers, retailers and distributors that the HID Electronic Ballast identified below bears an invalid cETLus Certification Mark and has not been evaluated by Intertek. It is unknown if this product is in compliance with the applicable safety standard. The number of Electronic ballast for HID bearing the invalid cETLus Certification Mark that have been produced or released into the market are unknown.

The products are easily identifiable as including a 277 V input rating and an ETL mark without a control number adjacent to it. Intertek has verified with the manufacturer that the subject products of this notice were not produced by them.

Name of Product: Electronic ballast for HID
Model: HPS/MH1000W
Brand/Manufacturer: SINOWELL (SHANGHAI) CO., LTD
Sold at: various retailers

Photos of Product:

